



**BUREAU  
VERITAS**

# Attestation of Conformity

**Attestation No.:** 1888AP1008N021008  
**Equipment:** Grid-connected PV Inverter

**Brand Name:**  **GOODWE**  
your solar engine

**Test Model No.:** GW36K-MT, GW30K-MT, GW25K-MT

**Applicant:** **Jiangsu GoodWe Power Supply Technology Co., Ltd.**  
No.189, Kun Lun Shan Road, Suzhou New District, Jiangsu 215163,  
P. R. China

**Report No.:** PVSP181008N021-1

## Use in accordance with regulations:

The previously listed inverters are three-phase and have an automatic disconnection / connection device controlled by software, in accordance with the regulations stated below. The end user will not have access to the adjustment software.

## Applied rules and standards

### UNE 206006:2011 IN

Island operation detection tests of multiple photovoltaic inverters connected to a parallel network

### UNE 206007-1:2013 IN

Requirements for connection to the electricity network Part 1: Inverters for connection to the distribution network

### DIN V VDE V 0126-1-1:2006-02 (Functional safety)

Automatic disconnection device between a generator and the public low-voltage network

**Name: James Huang**  
**Technical Manager/ New Energy Team**  
**Date: 2019-05-17**

This document shall not be reproduced, except in full, without the written approval of Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch.  
Information given in this document is related to the tested specimen of the described electrical sample.